



SECTION 08360

SECTIONAL OVERHEAD DOORS

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Sectional Overhead Doors

1.2 RELATED SECTIONS

- A. Section 04810-Unit Masonry Assemblies
- B. Section 05100-Structural Metal Framing
- C. Section 06100- Rough Carpentry
- D. Section 09900- Paints and Coatings
- E. Section 16050- Wiring Connections

1.3 REFERENCES

- A. ANSI/DASMA 102-American National Standard Specifications for Sectional Overhead Type Doors.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300
- B. Shop Drawings: Show in detail opening and clearance dimensions. Include elevations of sections and track. Include section finish, gauge and non standard options. Show detail of jamb material and connections.
- C. Verification Samples: Two samples, minimum 6 inches square, representing actual product selected.
- D. Operation and Maintenance data.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products in this

section with minimum five years experience.

- B. Installer Qualifications: Authorized representative of the manufacturer with minimum five years documented experience.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Store products in manufacturer's unopened packaging until installation.
- B. Store materials in a dry, weathertight location.

PART 2 PRODUCTS

2.1 MANUFACTURERS

Acceptable Manufactures: General Doors Corporation, which is located at One Monroe St.; Bristol, PA 19007; Tel: 215-788-9277; Fax 215-788-9450; Email: sales@general-doors.com; Web: www.general-doors.com

2.2 INSULATED STEEL SECTIONAL OVERHEAD DOORS

- A. General Doors Corporation Model 24 Gauge Insulated.
 - 1. Door Assembly: Roll formed steel pan type construction. Doors comply with:
 - a. ANSI/DASMA 102 – American National Standard Specifications for Sectional Overhead Type Doors.
 - 2. Door Model: 24 Gauge Insulated
 - 3. Panel Thickness: 2 inches
 - 4. Exterior Surface: Roll formed smooth surface with two deep reinforcing ribs and four shallow grooves.
 - 5. Exterior Steel: Pre-Painted 0.023 inches, hot dipped galvanized. Two coat baked on paint system, enamel primer and a 1.0 mil thick polyester finish coat.
 - 6. Insulation: 1-7/16" expanded polystyrene with an R-value of 7.0. Back covers shall be:
 - 7. End Stiles:
 - 8. Center Stiles: 18 Gauge
 - 9. Torsion Springs:
 - a.
 - 10. Windows:
 - 11. Exterior Colors:
 - a.
 - 12. Wind Load Design:
 - 13. Track and Operating Hardware:
 - 14. Hardware: Heavy duty galvanized hinges and fixtures. Floating ball bearing rollers with hardened steel races. Galvanized aircraft cables, 7x19 construction, minimum 5:1 safety factor.
 - 15. Lock:
 - 16. Track:
 - 17. Seals:
 - a. Vinyl weatherseal full width of door, bottom and top sections.
 - b. Standard continuous, replaceable dual seals between sections.

2.3 FABRICATION

- A. Check site dimensions prior to fabrication

PART 3 EXECUTION

08360-2

3.1 EXAMINATION

- A. Verify opening dimensions, jambs plumb, level and square

3.2 INSTALLATION

- A. Install assembly in accordance with manufacturer's instructions.
- B. Assemble work plumb, true, square, straight , level and accurate as per drawings
- C. Position jamb weather seal to contact door when closed.

3.4 ADJUSTING

- A. Adjust door to ensure smooth operation through open and close cycle. Use manufacturer approved lubricant on all bearings.

3.5 DEMONSTRATION

- A. Demonstrate proper operation to user.

END OF SECTION